

## TPW



# Water Cooled Package Unit

Cooling capacity: 29~165kw





# Turn To The Experts

Inheriting a rich legacy of innovation including inventing modern air-conditioning, Carrier has been a global leader in innovations for Heating Ventilation Air Conditioning (HVAC) and refrigeration solutions. Carrier is a part of UTC Climate, Controls & Security, a unit of United Technologies Corp., a leading provider to the aerospace and building systems industries worldwide.

With a broad portfolio of advanced technical patent awards, our global R&D center in Shanghai develops innovative heat, ventilation and air-conditioning (HVAC) solutions.



WATER-COOLED PACKAGE AIR CONDITIONER

Product Overview

Nomenclature

Performance Features

Specifications

**Cooling Capacity** 

Dimensions

Installation Requirements

System Connection Diagram

Pipe Connection

Electrical Wiring Drawing

**Electrical Parameters** 

Operating Range

Maintenance

## CONTENTS

1
1
1
3
4
5
8
8
9
9
10
10
11

## **Product Overview**

### **Overview**

TPW series water-cooled package unit (floor-standing type) is a new generation user-friendly unitary air conditioning unit launched by absorbing the latest designs at home and abroad and in combination with the actual usage. The product features mature technology, compact structure, simple installation, stable and reliable performance and high EER. It can be widely used in new or reconstructed industrial and commercial sites such as factory buildings, hospitals, schools, shopping malls, and banks.

The TPW series water-cooled package unit (floor-standing type) is classified into six models. Of which, TPW030 also supports direct discharge for scenarios where air supply pipe is not required, except for the standard air duct connection. The other models are standard duct type units.

## Nomenclature



## Features

## 1. Environmental-friendly

The units use eco-friendly refrigerant R410A. The chlorine-free refrigerant does not harm the ozone layer (zero-ODP), and is stable and non-toxic. It is green and unlikely to be replaced. Thanks to the high heat exchange coefficient, it can lower the power consumption.

## 2. Cutting-edge components

### High-efficiency scroll compressor

The units adopt the high-efficiency scroll compressors from a world-famous manufacturer. The compressor is featured by a small clearance capacity and small friction loss. Compared with the traditional semi-hermetic and full-hermetic piston compressors, it provides high reliability, high EER, and smooth and quiet operation.

All but TPW050FF that adopts one compressor in the series come with multiple compressors. In this way, multi-level energy regulation is attainable, partial load efficiency gets a boost, and operation is more energy-saving. Besides, the more balanced running time of compressors prolongs the service life of the unit.

### High-efficiency heat exchanger

The unit adopts a high-efficiency tube condenser, which lowers the requirement on the water quality, prevents scaling, and features excellent condensing and heat transmission performance. The heat exchanger is composed of the flat window hydrophilic aluminum foil and inner-threaded tubes. The large heat exchange area effectively improves the unit COP.







5

High-performance fans

The fan motor is at least IP55 rated. It can withstand hostile weather conditions such as gale and heavy rain, and ensure that the unit can operate safely and reliably in extreme weather conditions.



## 3. Reliability

The quality system is ISO 9001 certified, and a unique automatic detection technology is adopted in the production process to ensure air tightness of the system. The unit has been tested online by the performance testing lab to ensure that the unit performance meets the requirements.

The unit is equipped with multiple protection functions to ensure the operating stability and reliability.

- Communication fault protection
- High discharge temperature protection
- Large compressor current protection
- Small compressor current protection
- Low outlet water temperature protection
- High outlet water temperature protection
- Phase sequence protection

- Sensor failure protection
- Frequent startup protection
- Balanced wear
- High pressure protection
- Low pressure protection
- Fan overload protection
- Small water flow protection



## 4. Intelligent control

Microcomputer control system

The latest water-cooled package unit adopts the upgraded thirdgeneration microcomputer controller and wired controller. The thirdgeneration microcomputer controller integrates phase sequence detection and current detection, and provides a USB interface to facilitate maintenance of the unit, and update and upgrade of the control program. The controller automatically adjusts the operating status of the equipment according to the temperature and other related parameters to meet the requirements of indoor operating conditions, thus achieving the best effect.

## Remote power-on/off + centralized remote control + • building automation

The unit's control board provides interfaces for the remote wired control switch/mode switching interlock. By using the DIP switches, users can switch on and off the unit/switch between modes remotely. The reserved remote communication interfaces can realize remote monitoring and switch control of the unit. All the units of the series are equipped with an RS485 communication interface, support Modbus and Building Automation System (BAS), to easily implement centralized control and intelligent management of multiple modules.

### User-friendly UI

The series is equipped with optimized control programs, including one-tap start-up, compressor balancing, time setup, status display, fault bypass, automatic fault judgment, automatic fault processing, and automatic fault alarm display. In addition, multiple functions can be configured as required, such as timed on/off, weekend/holiday running, power-off memory, and multi-password protection.







# **Unit Selection Parameters**

## Specifications

Model		TPW	TPW030FF(Z)	TPW050FF	TPW065FF	TPW085FF	TPW130FF	TPW165FF		
Rated cooling capacity			29000	46000	61000	85000	127000	165000		
Cooling capacity range			0,50,100	0,100	0,30,70,100	0,50,100	0,33,66,100	0,25,50,75,100		
	Air flow	m³/h	5300	8000	11000	17000	22000	28800		
	ESP	Ра	100(0)	150	150	200	300	350		
	Power supply	-	380V 3N~ 50Hz							
	Power input	W	8300	13800	17500	23700	37200	45900		
Ν	laximum power input	W	10600	17400	20300	28000	43900	54500		
Max	imum operating current	A	20.07	32.95	40.42	53.03	83.14	103.22		
Charge amount	R410A	kg	1.5*2	3.5	3.0+1.3	3.1*2	3.1+3.4*2	3.4*4		
I	Compressor type	-		Scroll compressor						
	Evaporator type	-		Finned copper tube type						
	Туре	-	Efficient tube							
Condenser	Water flow	m³/h	6.24	9.89	13.12	18.28	27.31	35.48		
	Water pressure drop	mH <sub>2</sub> O	3.8	8.5	7.4	9.5	10.5	11.5		
Fee	Туре	-	Centrifugal fan							
Fan	Drive mode	-	Belt drive							
Air filter	Qty	Pcs	2	2	2	6	6	6		
All liller	Dimensions	mm	665*595	720*648	825*720	514*650	675*644	690*815		
Condensing Diameter of intermediate drainage pipe		DN	DN25(R1)							
drainage Diameter of bottom drainage pipe pipe		DN	DN25(R1)							
Size of cooling water connecting pipe			D-4.4/4	D 4 4/0	D-2	D-0.4/0	D 0 4/0	Rc2-1/2		
(Inner-threaded tube)			Rc1-1/4	Rc1-1/2	Rc2	Rc2-1/2	Rc2-1/2	RC2-1/2		
Dimensions	Length	mm	1470	1470	1810	2028	2420	2560		
	Width	mm	500	700	700	1100	1263	1263		
	Height	mm	1700	2000	2000	2030	2080	2360		
Weight	Cooling-only	kg	280	350	440	900	1060	1280		
E	nergy efficiency grade	-	1	1	1	1	1	1		

## **Cooling Capacity**

			mperature of ator (°C)	Water inlet temperature of condenser (°C)					
Model	Air flow (m <sup>3</sup> /h)	Dry bulb	Wet bulb temperature (°C)	18		30		34	
				Total cooling capacity	Sensible cooling capacity	Total cooling capacity	Sensible cooling capacity	Total cooling capacity	Sensible cooling capacity
TPW030FF		32	23	114%	118%	108%	104%	106%	99%
	5300	27	19	105%	105%	100%	100%	98%	98%
		21	15	95%	90%	90%	96%	89%	98%
		32	23	123%	116%	105%	104%	99%	100%
TPW050FF	8000	27	19	112%	105%	100%	100%	96%	98%
		21	15	98%	92%	94%	95%	92%	97%
	11000	32	23	115%	128%	109%	121%	107%	119%
TPW065FF		27	19	107%	119%	100%	100%	98%	94%
		21	15	96%	108%	89%	75%	87%	64%
	17000	32	23	116%	147%	109%	136%	107%	132%
TPW0850FF		27	19	107%	133%	100%	100%	98%	89%
		21	15	95%	116%	89%	57%	87%	38%
	22000	32	23	120%	115%	113%	105%	110%	101%
TPW130FF		27	19	110%	107%	100%	100%	97%	98%
		21	15	99%	97%	85%	94%	80%	93%
	28800	32	23	110%	110%	109%	102%	109%	100%
TPW165FF		27	19	107%	103%	100%	100%	98%	99%
		21	15	104%	96%	89%	97%	84%	97%

#### ★ Remarks

1. The cooling capacity test is based on the following conditions: indoor dry bulb temperature 27°C, wet bulb temperature 19°C; inlet water temperature 30°C, Water flow = Nominal cooling capacity \* 0.215 (m<sup>3</sup>/(h·kW)).

2. The cooling capacity does not take into account the heating loss of fan motor.

3. The external static pressure refers to the static pressure measured under normal air flow condition of standard configuration.

4. The numbers in brackets are applicable to the direct-blow fan type.

5. Specifications may be changed due to product improvement. Please refer to the nameplate label on the unit.

6. For the unit energy efficiency grade, refer to GB19576 The Minimum Allowable Values of the Energy Efficiency and Energy Efficiency Grades for Unitary

Air Conditioners.

# Dimensions

## TPW030FF



TPW050FF



TPW065FF



TPW085FF



Front

301 474 384 473 301 1988 Top view

<u>4-ø10.5</u>

1914 2028 2048

Front viev 1935

1432



## TPW130FF



## TPW165FF



## Installation Instructions

## Installation Requirements

- Do not install the unit in an open outdoor environment.
- Do not install the unit in an environment that is humid, corrosive or exposed to explosive gases.
- The unit adopts the "free return air" design. The equipment room serves as the return air room. If the return air goes from the duct into the unit, the air return flange must be changed and a winding connection pipe must be installed.
- The unit must be installed on the flat floor or a concrete base, which must be solid enough to withstand the weight of the unit during its operation.
- Install rubber or spring cushions at the fixing feet to avoid vibration and noise.
- During installation, the clearance for drainage, ventilation and maintenance must be reserved. Refer to the external dimension drawings of the unit for the minimum installation clearance.
- The unit and connecting pipes should be separated from the wall and ceiling during installation.
- Install the unit in a place least sensitive to sound, e.g., near a stairwell, elevator room or toilet. A better way of sound insulation is to use partitions between the unit and the air conditioning room, and seal the doors and windows. Silencers or sound absorbing cotton can also be used in the air duct if necessary.

## System Connection Diagram





Service valve



## **Pipe Connection**

- All piping systems should be installed in compliance with local regulations. Do not bend or move pipes up or down unless you must.
- To reduce the vibration and noise transmission of the pump, a flexible connecting pipe can be installed on the suction and discharge pipes of the pump.
- To ensure constant condensation pressure and temperature, a three-way water flow regulating valve can be used to adjust the water flow into the condenser. The valve must be set to maintain the minimum inlet water temperature at 18°C.
- To prevent the water temperature from being too low, a temperature switch can be installed (the recommended water temperature is 27°C) to control the cooling tower fan, thus maintaining the water temperature in the normal range.
- The condensate water drain pipe is connected from the evaporator drain pan (the unit chassis is equipped with a drain pan for emergency drainage only).
- In order to prevent external air from entering the evaporator and facilitate the drainage of condensate water, a small offset bend (water lock) can be installed 51 mm below the drain pipe.
- The drain pipe should stretch outside the wall of the building to prevent the drained water from flowing onto the wall.
- The water pipes should be insulated to prevent dripping of the condensed water.
- The pump suction pipe segment and the condenser outlet of air conditioner must be equipped with service valves, and the pump outlet must be equipped with a water flow regulating valve. Do not use the pump outlet valve to adjust water pipes.

### Electrical wiring diagram (with cooling requirement in winter)



Note: If there is any requirement for refrigeration in winter, it is recommended to follow the wiring diagram.

Add a temperature control switch (marked by the dotted line in the figure) that detects the cooling water to control the operation of the cooling tower fan motor.

## **Electrical Parameters**

Model			TPW030FF(Z)	TPW050FF	TPW065FF	TPW085FF	TPW130FF	TPW165FF			
Po	ower supp	oly	380 3N~50Hz								
Main line (R/ S/T)		Sectional area (mm <sup>2</sup> )	4 10		16	25	35	70			
		Pieces	3								
Power	Neutral	Sectional area (mm <sup>2</sup> )	4	10	10	16	25	35			
cord	line	Pieces	1								
GND	GND	Sectional area (mm <sup>2</sup> )	4	10	16	16	16	35			
		Pieces	1								

#### ★ Notes

The power cord specifications of this table are based on the maximum power (maximum current) of the unit for the PVC insulated copper core cable laid in the air under the ambient temperature of 40°C. Please refer to the electrician manual and the power cord specifications of the wire and cable manufacturer if your installation conditions are different or de-rate the unit if it is necessary.

## **Operating Range**

The TPW unit is connected to a single power supply without any additional control power. The power supply of the unit is 380V/3N~/50Hz, and the control power supply is 220V~/50Hz. Protection measures include compressor overload protection, motor winding protection, high and low system pressure protection and etc.

Power supply		Voltage range (V)	Water inlet temperature of the condenser (°C)	Evaporator air inlet	
Compressor	Fan	342~420	16~40	Wet bulb temperature (°C)	Dry bulb temperature (°C)
380 3N~50Hz	380 3N~50Hz	542~420		13~24	20~32

### Maintenance

The TPW units are highly automated devices. Therefore, check the operation status periodically. Long-term and effective maintenance can greatly enhance the operation reliability of the unit and prolong the unit's service life.

- Clean the water filter installed outside the unit periodically to ensure the cleanliness of water in the system and prevent unit damage caused by clogging of the filter. While using and maintaining the unit, do not adjust any of the safety devices, which have been set properly before shipping. TICA is not liable for any damage of the unit caused by unauthorized adjustment.
- Do not pile up any debris around the unit, which may block the air inlet and outlet of the unit. Keep the unit clean, dry and well ventilated. Clean the air-side heat exchanger periodically (once 1-2 months) to maintain excellent heat transfer effect and save energy.
- Regularly check whether the water refill and air discharge devices of the water system work properly. Air may enter the system and cause low water circulation or water circulation difficulties, affecting the cooling effect of the unit as well as the reliability of the unit.
- Check whether wiring of the unit power supply and electrical system is secure, and whether electrical components work abnormally. If an exception occurs, repair or replace electrical components. Check whether the unit is grounded reliably.
- Check the working conditions of each component of the unit regularly and check whether the work pressure of the cooling system of the unit is within the normal range. Check whether there are oil dirt on the pipeline connectors and inflation valves of the unit to ensure that the cooling system does not leak.
- If the unit is not used for long after one running period ends, drain water out of the unit pipeline, cut off power and install the protection sleeve (not installed on the unit at factory). Fill water into the system and conduct an overall check on the unit before starting the unit again. Then, electrify the unit to preheat it for more than 6 hours, and then start the unit and put it into normal operation after confirming that everything is OK.





